



**GENERAL NOTES:**

- (1) INSTALL CONNECTOR LINE FROM EXISTING BLOW OFF ASSEMBLY TO NEW MAIN FOR FILLING, TESTING AND STERILIZING NEW MAIN.
- (2) CONNECTOR LINE TO BE ASSEMBLED WITH RPZ AND METER BY CONTRACTOR AND TO BE OPERATED AND INDEPENDENT OF EXISTING MAIN.
- (3) BLOCKING ON EXISTING LINE NOT TO BE DISTURBED.
- (4) FINAL CONNECTION TO EXISTING MAIN TO BE MADE ONLY AFTER TOTAL PROJECT IS ACCEPTED BY UNION COUNTY PUBLIC WORKS.
- (5) VALVES ON EXISTING SYSTEM TO BE OPERATED BY UCPW FORCES ONLY.
- (6) ONLY ONE CONNECTION WILL BE ALLOWED BETWEEN THE EXISTING SYSTEM AND THE NEW CONSTRUCTION UNTIL TESTING AND DISINFECTION IS COMPLETE.
- (7) 6" OR 8" DIAMETER PIPE= 40 LF OF STUB, 12" OR 16" DIAMETER PIPE= 72 LF OF STUB

STANDARD DETAIL

UNION COUNTY PUBLIC WORKS DEPARTMENT  
UNION COUNTY, N.C.

# JUMPER CONNECTION

SCALE:  
N.T.S.  
DATE:  
9-2-10

# 25