



NOTES:

1. NO PIPE SHALL BE SUPPORTED BY BELL.
2. END SECTIONS LESS THAN 4' MAY BE UNSUPPORTED.
3. WALL THICKNESS AS PER TABLE UNLESS OTHERWISE SHOWN ON PLAN.
4. MASONRY SEAL AT ENDS -- 2" x 4" WEEP HOLE AT LOW END
5. ALL PRESSURE PIPES TO HAVE TRACING WIRE IN ALL CASING BORES.

CARRIER PIPE	CASING PIPE I.D.	WALL THICKNESS
4"	8"	0.188"
6"	12"	0.188"
8"	16"	0.250"
10"	16"	0.250"
12"	20"	0.281"
16"	24"	0.344"
24"	30"	0.406"
30"	42"	0.500"
36"	48"	0.500"

UNION COUNTY PUBLIC WORKS DEPARTMENT  
UNION COUNTY, N.C.

STANDARD DETAIL

# PIPE ENCASEMENT

SCALE:  
N.T.S.  
DATE:  
11-17-06

14